

FIRE INSPECTION REPORT
Flower Mound Fire Department
 3838 Forums Drive
 FLOWER MOUND TEXAS 75028
 OFFICE: (972) 874-6270 FAX: (972) 874-6470
 www.flower-mound.com



BUSINESS NAME _____ **CONTACT** _____

ADDRESS _____ **SUITE** _____ **TELEPHONE NUMBER** _____

INSPECTION DATES _____
 (Initial inspection) (1st Re-inspection) (2nd Re-inspection)

TOTAL # VIOLS.	DAYS TO CLEAR	DATE CLEARED	CLEARING INSPECTOR	Type of compliance ordered
				COMPLIANCE REQUIRED: () IMMEDIATE () 24 HOUR () 48 HOUR () DAYS TO CLEAR
				1. All fire lanes or fire zones are painted and labeled per the Fire Marshal's Policy
				2. Address, building or suite numbers are provided and visible on the street side of the building
				3. Address or suite numbers are provided on () gas meters () electric meters and/or () rear suite doors
				4. Perimeter of building is free of accumulation of weeds, trash, tires and other debris
				5. () Knox box is provided with a current set of keys and/or codes () Opticom devices operate properly
				6. () Certificate of Occupancy is posted () NFPA 704 placards posted where required
				7. () Exit signs and/or () emergency lights work () self- illuminating signs in approved occupancy
				8. Exit doors are free of double key locks, pad locks, drop bars and slide bolts
				9. Exit doors, corridors, hallways and stairways are free of obstructions
				10. Below exit stairways and attic spaces are free of combustible storage
				11. All equipment, fire sprinkler, mechanical and electrical rooms are labeled and free of storage
				12. All storage rooms are clean and orderly with ceiling clearance of 18 to 24 inches
				13. 30 inch clearance is maintained in front of all electrical panels
				14. Flammable/combustible liquids are stored in approved occupancies and containers/cabinets
				15. Fueled equipment is only stored, operated or repaired in an approved occupancy
				16. Electrical wiring and equipment is in good condition
				17. () Electrical extension cords are properly utilized and () multiple outlet adapters are approved type
				18. All gas appliances have approved tubing, connectors and the vent piping is in place
				19. () Approved type and size of fire extinguishers are installed () Inspection tag is current
				20. Fire alarm system is in service, unobstructed and the BLUE TAG is current and in APPROVED status
				21. Fire sprinkler system is in service and the BLUE TAG is current and in APPROVED status
				22. Fire suppression system has a current and APPROVED status with a semi-annual (6 months) service tag

COMMENTS: _____

() No violations noted () Inspection complete and returned for filing

This inspection was performed for the purpose of pre-fire planning, identifying hazards and life safety compliance. To be compliant with the Town of Flower Mound Fire Code, you are requested to correct the *VIOLATIONS* noted on this report on or before the designated re-inspection dates. Failure to comply by the dates noted may result in fines assessed by citation for each offense. Each item and each day will constitute a separate offense. By signing this report, you are acknowledging that these violations have been brought to your attention and that you will comply or will forward this report to the appropriate representative for compliance. If you do not agree with the findings of this report, you must provide in writing to the Fire Marshal a letter explaining why you should not comply. Otherwise, you are required to comply by the dates noted.

Owner/Occupant _____ **Signature** _____ **Date** _____
 (Print Name)

Inspector _____ **ID Number** _____ **Date** _____
 (Print Name)